

State of California

AIR RESOURCES BOARD

Executive Order G-70-6

Relating to the Certification of the OPW System Y Type 2,  
Vapor Recovery System for Underground Storage Tanks  
at Gasoline Service Stations


Pursuant to the authority vested in the Air Resources Board by Health  
and Safety Code Section 41954; and

Pursuant to the authority vested in the undersigned by Health and Safety  
Code Sections 39515 and 39516;

IT IS ORDERED AND RESOLVED: that, except as provided below, the Dover  
Corporation, OPW Division, System Y, Type 2, vapor recovery system, with  
or without a pressure-vacuum valve, is hereby certified for use on  
underground gasoline storage tanks at service stations. The system  
certified hereby is shown in Exhibit I, attached.


IT IS FURTHER ORDERED AND RESOLVED: that use of the pressure-vacuum  
valve be subject to approval of the local fire chief, and that the tanks  
and piping be in compliance with the appropriate General Industry Safety  
Orders and in particular the provisions in Articles 144, 145, and 146  
thereof.

Executed at Sacramento, California, this 26<sup>th</sup> day of April 1977.

  
William H. Lewis, Jr.  
Executive Officer

# EXHIBIT 1

## OPW SYSTEM Y TYPE 2 VAPOR RECOVERY SYSTEM



### PARTS LIST (Note 1)

- |   |  |
|---|--|
| (1) P/V Valve (optional). (Note 1 & 2).                                   | (5) OPW 61-TD Aluminum drop tube (extend to within 6" bottom of tank). |
| (2) OPW 1611-AV 3" Dry break with an OPW 1711T or OPW 1711TK Locking cap. | (6) OPW 61AS Adapter or OPW 633T Adapter.                              |
| (3) OPW 1711-V3" Elbow.   | (7) OPW 60 Elbow or OPW 60T Elbow.                                     |
| (4) 2" Vent pipe.   | (8) OPW 318-VM Y-Type Fitting.   |

#### Notes:

1. Interchangeable fittings, dust caps, and P/V valves are given in Executive Order G-70-2-B.
2. Vent pipes may be manifolded.